



Embassy of the United States of America

Tokyo, Japan

June 9, 2020

To: All Prospective Offerors

From: Darin A. Phaovisaid, Contracting Officer

Subject: Question-and-Answer (Q&A) Correspondence No. 1

Reference: Request For Quotations No. 19JA80-20-Q-0690
Acquisition of Dehumidifiers for U.S. Embassy Tokyo

In response to questions received in regard to the referenced solicitation, the Contracting Officer is disseminating the following information:

Question 1:

"Please kindly let us know if you are able to accept Dehumidifiers with USA Voltage 110Volt (+/- 10%) 60Hz or 220Volt/ 50Hz with Transformer."

Answer 1:

No. The dehumidifiers are to be used in U.S. Embassy apartment compound in Tokyo, Japan, and the required voltage is 120 Volt, 50 Hz.

-End of Q&A Correspondence No. 1-